



No. UW17/06

File Copy

Permit

Issued Pursuant to Section 5 of the *Water and Sewerage Act*

Applicant

O'Leary Sewage Collection
And Treatment Corporation

Date Application Filed

May-25-2017

Engineer

WSP/Gallant

Project Description

This project involves upgrades to O'Leary's lagoon cell #2, the replacement of six manholes and the installation of 250 metres of sewer main, as well as the installation of a new UV disinfection system and the addition of a solar powered mixer to lagoon cell #1. Project No. 161-13721, Preliminary Drawings C01-07 and E01-02, dated May-19-2017.

Cost Estimate

\$856,000

IRAC Approval

Jun-07-2017

Conditions of Permit

1. Total sewer project costs, including inspection and engineering, to be cost shared per the application dated May 24, 2017.
2. Project to be awarded via public tendering.
3. Easement(s) to be obtained where main(s) cross(es) private property (where applicable).
4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when available.
5. Prior to commencement, project must receive approval from the Department of Communities, Land and Environment.
6. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein.

Issued at Charlottetown, June 7, 2017

Original Signed by A. MacEwen

Director, Regulatory Services