



No. UW19/03

File Copy

# Permit

**Issued Pursuant to Section 5 of the *Water and Sewerage Act***

<b>Applicant</b>	<b>Date Application Filed</b>	<b>Engineer</b>
Wellington Sewer Utilities Corporation	Apr-17 & Apr-22-2019	CBCL - Hughes

**Project Description**  
 Project involves the upgrading of the existing lift station off Ellis River Drive in Wellington. The project includes the replacement of the wet well, a new control panel with service entrance, utility metering and the reconnection of the existing emergency generator. Project No. 182616.00, Preliminary Drawings C01 - 03 & E01 - 02, stamped April 16, 2019.

<b>Cost Estimate</b>	<b>IRAC Approval</b>
\$350,786	Apr-30-2019

- Conditions of Permit**
1. Total sewer project costs, including inspection and engineering, to be funded 100% in accordance with the application dated April 22, 2019.
  2. Project to be awarded via public tendering.
  3. Easement(s) to be obtained where main(s) cross(es) private property (wherever applicable).
  4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when available.
  5. Prior to commencement, project must receive approval from the Department of Communities, Land and Environment.
  5. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein.

**Issued at Charlottetown, April 30, 2019**

*Original Signed by A. MacEwen*

**Director, Regulatory Services**