



No. UW21/05

Permit

Issued Pursuant to Section 5 of the *Water and Sewerage Act*

Applicant	Date Application Filed	Engineer
Borden-Carleton Water and Sewage Utility	Sep-15-2021	WSP/MacLean

Project Description

This project involves the replacement of four epoxy-coated steel panels on the bottom of Borden-Carleton's water tower with new glass-fused steel panels. The tower will be drained, the old panels will be removed and replaced, and the tower will be refilled upon completion of the work. In addition, the lowering and raising of the tower will follow environmental procedures. WSP Project 211-0812.

Cost Estimate

\$385,000

IRAC Approval

Oct-01-2021

Conditions of Permit

1. Total water project costs, including inspection and engineering, to be funded in accordance with the application dated September 15, 2021.
2. Project to be awarded via public tendering (minimum of three bidders).
3. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
4. Certificate of inspection by design engineer and detailed final contract costs to be filed with the Commission, when project completed.
5. Prior to commencement, project must receive approval from the Department of Environment, Energy and Climate Action.
6. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein.

Issued at Charlottetown, October 1, 2021

Original Signed by A. MacEwen

Director, Regulatory Services