



No. UW22/02

# Permit

## Issued Pursuant to Section 5 of the *Water and Sewerage Act*

### Applicant

Granville on the Water

### Date Application Filed

May-19-2022

### Engineer

CBCL/Hughr

### Project Description

Project Involves the addition of 330m of 100 mm dia. Watermain, 335m of 65mm dia. Watermain, 2 Flushing Hydrants, 21 Domestic Services(25 dia.), Booster Station 3m x 3.6m Duplex 2 Hp Pumps, Pressure Control VFD. CBCL project 212650, preliminary drawings C01-04, E01, issued May-19-2022.

### Cost Estimate

\$275,000

### IRAC Approval

Jul-05-2022

### Environment Approval

Aug-05-2022

### Conditions of Permit

1. Total sewer project costs, including inspection and engineering, to be funded in accordance with the application dated May 19, 2022.
2. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
3. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when completed.
4. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein.

Issued at Charlottetown, August 15, 2022

*Original Signed by A. MacEwen*

Director, Regulatory Services