



No. UW24/01

File Copy

Permit

Issued Pursuant to Section 5 of the *Water and Sewerage Act*

Applicant	Date Application Filed	Engineer
Montague Sewer & Water Corporation	April 4, 2023	CBCL Engineering

Project Description

This project involves extending Montagues existing water and sanitary systems from Robertson Rd to MacDonald Rd. New lift station near Nicholson Rd. Sewermain totals: 345m @ 300mm, 1270m @ 250mm, 240m @ 200mm, 290m @ 200mm forcemain, 20-1050mm mhs, 1-2400mm Duplex LS. Watermain totals: 1880m @ 300mm, stubs at Robertson Rd (200mm), Crescent Ln (150mm), and Nicholson Rd (200mm), 7 fire hydrants and 10 main line valves. CBCL project 222625.00, preliminary drawings C01-C12, and E01-E02, issued March 2023.

Cost Estimate	IRAC Approval	Environment Approval
\$4,534,000	January 5, 2024	April 14, 2023

Conditions of Permit

1. Total water & sewer project costs, including inspection and engineering, to be funded in accordance with the application dated April 4, 2023.
2. Project to be awarded via public tendering (minimum of three bidders).
3. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when completed.
5. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein.

Issued at Charlottetown, May 9, 2024

Original Signed by A. MacEwen

Director, Regulatory Services