



No. UW24/04

File Copy

Permit

Issued Pursuant to Section 5 of the *Water and Sewerage Act*

Applicant	Date Application Filed	Engineer
Miscouche Sewer Utility Corporation	May 15, 2024	WSP Canada Inc.

Project Description

This project involves extending the existing 200mm diameter sanitary gravity main along Kinsman road by approximately 90 meters. The project also involves the addition of 3 new 100mm diameter services off of the existing main and 1 new 150mm diameter service off of the new main. WSP Canada Inc. project CA0030924.0577, preliminary drawing C01-02, issued May 2024.

Cost Estimate	IRAC Approval	Environment Approval
\$176,442	June 5, 2024	May 22, 2024

Conditions of Permit

1. Total water & sewer project costs, including inspection and engineering, to be funded in accordance with the application dated May 15, 2024.
2. Project to be awarded via public tendering (minimum of three bidders).
3. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when completed.
5. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein.

Issued at Charlottetown, June 5, 2024

Original Signed by A. MacEwen

Director, Regulatory Services