



No. UW25/06

File Copy

Permit

Issued Pursuant to Section 5 of the *Water and Sewerage Act*

Utility

Georgetown Water Utility

Date Application Filed

September 25, 2025

Engineer

CBCL Limited

Project Description

This project involves the construction of a new watermain, and twinning a portion of the existing watermain along Kent Street and the extension of the existing system from Kent Street to East Royalty Road to connect onto a pipe stub left from the Georgetown Business Park. Project includes approximately 300m of 200mm dia. PVC watermain c/w 4-valves, 3-tees, and 4-bends. CBCL Project no. 222612.06, preliminary drawings C01-C05, issued July-31-2025.

Cost Estimate

\$250,800.00

IRAC Approval

October 28, 2025

Environment Approval

Permit #: P2025-31
August 5, 2025

Conditions of Permit

1. Total water & sewer project costs, including inspection and engineering, to be funded in accordance with the application dated September 25, 2025.
2. Project to be awarded via public tendering (minimum of three bidders).
3. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when completed.
5. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein. Any amendments to the scope of the project without prior approval by the Commission may result in the revocation of this approval.

Issued at Charlottetown, October 28, 2025

Original Signed by S. Clow

Regulatory Services