



No. UW26/01

# Permit

**Issued Pursuant to Section 5 of the *Water and Sewerage Act***

## Utility

Hunter River Sewerage Collection  
and Treatment Utility Corporation

## Date Application Filed

February 2, 2026

## Engineer

CBCL Limited

## Project Description

This project involves the upgrade of the existing lift station at the corner of Route 2 and 13 in Hunter River. This project includes the installation of new duplex Flygt NP3085.070 MT pumps (3.0 HP, 7.0 L/s @ 9.4 m TDH), associated piping, alarms and valves, access hatches, electrical upgrades and a standby generator. The construction will include a separate fiberglass valve chamber enclosure and a concrete pad for the generator along with upgrades to three phase power.

## Cost Estimate

\$532,659.00

## IRAC Approval

April 24, 2026

## Environment Approval

Permit #: P2026-02  
January 28, 2026

## Conditions of Permit

1. Total water & sewer project costs, including inspection and engineering, to be funded in accordance with the application dated February 2, 2026.
2. Project to be awarded via public tendering (minimum of three bidders).
3. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when completed.
5. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein. Any amendments to the scope of the project without prior approval by the Commission may result in the revocation of this approval.

**Issued at Charlottetown, April 28, 2026**

*Original Signed by C. Bradley*

**Regulatory Services**