



No. UW26/03

File Copy

Permit

Issued Pursuant to Section 5 of the *Water and Sewerage Act*

Utility

Alberton Sewage Collection
and Treatment Corporation

Date Application Filed

January 13, 2026

Engineer

WSP Canada Inc.

Project Description

This project involves the extension of the wastewater collection system for the Town of Alberton to service a new subdivision that will include both residential and commercial developments. The subdivision will require the construction of a new lift station that will include duplex Flygt NP-3085 pumps (3 HP, 8.9 L/s @ 4.3 m TDH), associated piping, alarms, valves, standby generator (30 kW) and electrical components. The upgrades to the collection system also includes the installation of 664 meters of 200 mm PVC SDR35 S/M; 82m of 100 mm PVC SDR26 F/M; sewer service laterals, manholes, misc. pipe and connections, fittings, sediment control, reinstatement and engineering.

Cost Estimate

\$1,430,218.00

IRAC Approval

June 30, 2026

Environment Approval

Permit #: P2026-03
March 3, 2026

Conditions of Permit

1. Total water & sewer project costs, including inspection and engineering, to be funded in accordance with the application received January 13, 2026.
2. Project to be awarded via public tendering (minimum of three bidders).
3. Easement(s) to be obtained where main(s) cross(es) private property (if applicable).
4. Certificate of inspection by design engineer, as-built plans and detailed final contract costs to be filed with the Commission, when completed.
5. This Permit expires if project not completed within twelve (12) months of the Permit issuance date.

This Permit, when signed below, authorizes the Applicant to proceed with the project described above subject to the conditions contained herein. Any amendments to the scope of the project without prior approval by the Commission may result in the revocation of this approval.

Issued at Charlottetown, July 2, 2026

Original Signed by C. Bradley

Regulatory Services